

TYPICAL TRENCH



UNSTABLE SUBGRADE

NOTES:

1. NEW STREET SURFACE SHALL COMPLY WITH LOCAL JURISDICTION.
2. TRENCH WALLS TO BE SUPPORTED AS REQUIRED BY OSHA.
3. FLOWABLE FILL AND FLASH FILL SHALL NOT BE USED AROUND OR ADJACENT TO DISTRICT FACILITIES.

REV. DATE:	10/2026	TRENCH CROSS SECTION
SCALE:	N.T.S.	

NTTM
NORTH TABLE MOUNTAIN WATER AND SANITATION DISTRICT
14806 WEST 52ND AVENUE GOLDEN, COLORADO 80403-1228

DWG. NO. W1

P:\Engineering\Standard Drawings\Standard drawing.dwg, 10/12/2026 11:57:39 AM