

PLAN



ELEVATION

CONTRACTOR SUPPLIED MATERIALS:	
ITEM	MATERIALS
CURB STOP	MUELLER (B25209), FORD BALL (TYPE B44-333-Q) OR EQUAL
SERVICE LINE	TYPE "K" COPPER (CONTINUOUS, NO FITTINGS)
CURB BOX	TYLER SERIES 6500 W/ ADJUSTABLE SERVICE BOX (#94E)
METER PIT	48" DIAMETER PRECAST CONCRETE
METER PIT COVER	24" Ø MH RING AND COVER W/ 2" PREDRILLED HOLE FOR METER ANTENNA
BEDDING MATERIAL	WASHED SAND OR SQUEEGEE MATERIAL
GRADE BEAM	12" X 12 X 8' PRECAST CONCRETE BEAM
YOKE	MUELLER B2423
CORPORATION STOP	MUELLER B25008
INSULATOR	REQUIRED WHEN TAPPING METAL PIPE
SADDLE ON PVC MAINS	MUELLER H-13000 SERIES- OR APPROVED EQUAL
TRACER WIRE	TRACER WIRE PER DRAWING NO. W11

NOTES:
1. ALL METAL SHALL BE LEAD FREE

REV. DATE:	10/2024	1-1/2" & 2" METER MANHOLE	
SCALE:	N.T.S.		
		NORTH TABLE MOUNTAIN WATER AND SANITATION DISTRICT	DWG. NO.
NTM		14806 WEST 52ND AVENUE GOLDEN, COLORADO 80403-1228	W9