


PLAN

PROFILE

NOTES:

1. THE BASE SLAB SHALL BE POURED MONOLITHICALLY (MAY BE SQUARE) WITH BOTTOM RISER SECTION. PRECAST MANHOLE BASES SHALL FIT THE CONDITIONS AND LOCATIONS FOR WHICH THEY ARE INTENDED WITHOUT ANY FIELD MODIFICATIONS.
2. PRECAST MANHOLE BASES SHALL BE BEDDED ON AN APPROVED GRANULAR BEDDING MATERIAL, PER SPECIFICATIONS.
3. SET EACH MANHOLE RING (OUTER AND INNER JOINT) IN TWO (2) FULL BEDS OF BITUMINOUS MASTIC (RAMNECK) OR PLASTIC SEALING COMPOUND.
4. DESIGN PLANS SHALL INDICATE INVERT (INLET AND OUTLET) ELEVATIONS.
5. MANHOLE TO PIPE CONNECTIONS SHALL BE CONSTRUCTED WITH A COMPRESSION-TYPE FLEXIBLE CONNECTOR, CAST INTO THE MANHOLE WALL PER SPECIFICATIONS.
6. MANHOLE SHALL BE WATER TIGHT.
7. VERTICAL ADJUSTMENT RINGS SHALL BE SEALED WITH AN EXTRUDED BUTYL ADHESIVE TAPE (EZ-WRAP BY PRESS-SEAL GASKET CORP. OR EQUAL).
8. FORMED FLOW CHANNEL IN BENCH SHALL MATCH O.D. OF PIPE.

9. IF MANHOLE LID IS IN PAVEMENT RECESS IT 0.5".
10. MANHOLE INTERIOR COATING SHALL BE REQUIRED IN ANTICIPATED HIGH H₂S AREAS, AS DETERMINED BY DISTRICT ENGINEER.
11. ALL MANHOLES WITH ECCENTRIC CONES SHALL BE ALIGNED WITH THE MANHOLE LIDS TOWARD THE ROAD CENTERLINE.
12. ALL OUTSIDE JOINTS OF RISER RINGS SHALL BE GROUTED, USING MORTAR MIXED WITH TYPE-V CEMENT.
13. ALL MANHOLES MUST PASS A VACUUM PRESSURE TEST, AS OUTLINED IN SEWER NOTES.
14. CONCRETE IN POURED BASES MUST BE VIBRATED TO ENSURE THERE ARE NO AIR POCKETS.

REV. DATE:	01/2020	SAMPLING MANHOLE DETAIL	DWG. NO.
SCALE:	N.T.S.		
		NORTH TABLE MOUNTAIN WATER AND SANITATION DISTRICT	S7
14806 WEST 52ND AVENUE GOLDEN, COLORADO 80403-1228			